



Department of Safety and Professional Services
Division of Industry Services
Plumbing Product Review
4822 Madison Yards Way
P.O. Box 7162
Madison, Wisconsin 53707-7162
Phone 608-266-2112
Web <http://dsps.wi.gov>
Email dsps@wisconsin.gov
TTY: Contact Through Relay

Governor Tony Evers Dawn Crim, Secretary

March 16, 2021

Dept. of Safety & Professional Services
Division of Industry Services
Michael McNally - Section Chief
1400 E Washington Ave
Madison WI 53703

Re: Description: Alternate Product Review
Manufacturer: Dept. of Safety and Professional Services
Product Name: Minimum Shower Waste Outlet Diameter
Model Number(S): None
eSLA PTO No.: PP-061603538-PTOAA

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (L) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2026.

This alternate approval is contingent upon compliance with the following stipulation(s):

1. This approval permits 1½ in. diameter p-traps to be used when installing *non-public* replacement showers in place of existing bathtubs.
2. Traps shall conform to s. SPS 382.32 Wis. Adm. Code.
3. All plumbing shall be installed by Wisconsin licensed plumbers.
4. The shower shall have one control valve and one shower head.
5. The shower head shall have a maximum flow rate of 2.5 gallons per minute (gpm).
6. It shall be permissible under this approval to use a diverter valve that feeds up to two showerheads provided the showerheads cannot be used simultaneously.

The department is in no way endorsing this alternate method and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 **Phone**
glen.schlueter@wi.gov **E-mail**
7:45AM-4:30PM CST M-F **Work Hours**